



**Ministry of Health and
Long-Term Care**
**Inspection Report under
the Long-Term Care
Homes Act, 2007**

**Ministère de la Santé et des
Soins de longue durée**
**Rapport d'inspection
prévue le Loi de 2007 les
foyers de soins de longue**

Health System Accountability and Performance

Division
Performance Improvement and Compliance Branch
Division de la responsabilisation et de la
performance du système de santé
Direction de l'amélioration de la performance et de la
conformité

London Service Area Office
291 King Street, 4th Floor
LONDON, ON, N6B-1R8
Telephone: (519) 675-7680
Facsimile: (519) 675-7685

Bureau régional de services de London
291, rue King, 4^{ème} étage
LONDON, ON, N6B-1R8
Téléphone: (519) 675-7680
Télécopieur: (519) 675-7685

Public Copy/Copie du public

Date(s) of inspection/Date(s) de l'inspection	Inspection No/ No de l'inspection	Type of Inspection/Genre d'inspection
Oct 26, Nov 16, 2011	2011_093145_0023	Complaint

Licensee/Titulaire de permis

MACGOWAN NURSING HOMES LTD
719 Josephine Street, P.O. Box 1060, WINGHAM, ON, N0G-2W0

Long-Term Care Home/Foyer de soins de longue durée

BRAEMAR RETIREMENT CENTRE
719 Josephine Street North, R.R. #1, P.O. Box 1060, WINGHAM, ON, N0G-2W0

Name of Inspector(s)/Nom de l'inspecteur ou des inspecteurs

KARIN MUSSART (145)

Inspection Summary/Résumé de l'Inspection

The purpose of this inspection was to conduct a Complaint inspection.

During the course of the inspection, the inspector(s) spoke with The Director of Care and the Environmental Services Supervisor.

During the course of the inspection, the inspector(s) Reviewed home's policy and procedures relating to temperature; reviewed temperature logs; observed temperatures while in home.

The following Inspection Protocols were used during this inspection:

Safe and Secure Home

Findings of Non-Compliance were found during this inspection.

NON-COMPLIANCE / NON-RESPECT DES EXIGENCES

Legend

WN – Written Notification
VPC – Voluntary Plan of Correction
DR – Director Referral
CO – Compliance Order
WAO – Work and Activity Order

Legendé

WN – Avis écrit
VPC – Plan de redressement volontaire
DR – Alguillage au directeur
CO – Ordre de conformité
WAO – Ordres : travaux et activités



Ministry of Health and
Long-Term Care
**Inspection Report under
the Long-Term Care
Homes Act, 2007**

Ministère de la Santé et des
Soins de longue durée
**Rapport d'inspection
prévue le Loi de 2007 les
foyers de soins de longue**

<p>Non-compliance with requirements under the Long-Term Care Homes Act, 2007 (LTCHA) was found. (A requirement under the LTCHA includes the requirements contained in the items listed in the definition of "requirement under this Act" in subsection 2(1) of the LTCHA.)</p> <p>The following constitutes written notification of non-compliance under paragraph 1 of section 152 of the LTCHA.</p>	<p>Le non-respect des exigences de la Loi de 2007 sur les foyers de soins de longue durée (LFSLD) a été constaté. (Une exigence de la loi comprend les exigences qui font partie des éléments énumérés dans la définition de « exigence prévue par la présente loi », au paragraphe 2(1) de la LFSLD.)</p> <p>Ce qui suit constitue un avis écrit de non-respect aux termes du paragraphe 1 de l'article 152 de la LFSLD.</p>
---	---

WN #1: The Licensee has failed to comply with O.Reg 79/10, s. 21. Every licensee of a long-term care home shall ensure that the home is maintained at a minimum temperature of 22 degrees Celsius. O. Reg. 79/10, s. 21.

Findings/Faits saillants :

1. No temperatures were taken in the evenings in the lounge or dining rooms for the month of September. For the temperatures taken in the evening in the wings, no time notations were recorded on Sept 2, 4 or 5th.
2. No temperatures were recorded at all for the month of October.
3. On Sept. 1, 2011 @ 0815 and again on the evening shift @ 1600, both in Yellow wing, the temperatures recorded were 20 deg. C and 21 deg. C. respectively. No action noted relating to the temperature being below 22 deg. C. On Sept. 2, 2011 at 0800 in Yellow wing was 21 deg. C. On September 5, 2011 @ 1000 in Yellow wing the temperature was recorded at 19 deg. C. with no actions noted to correct the below minimum 22 deg. C. Also, on September 5, 2011, the temperature in the Dining Room @ 0900 was noted to be 20 deg. C.
4. Temperatures have not been taken in the home since Sept. 5, 2011.

Issued on this 16th day of November, 2011

Signature of Inspector(s)/Signature de l'inspecteur ou des inspecteurs