



Inspection Report under the *Long-Term Care Homes Act, 2007*

Rapport d'inspection prévue le *Loi de 2007 les foyers de soins de longue durée*

Ministry of Health and Long-Term Care

Health System Accountability and Performance Division
Performance Improvement and Compliance Branch

Ministère de la Santé et des Soins de longue durée

Division de la responsabilisation et de la performance du
système de santé
Direction de l'amélioration de la performance et de la
conformité

London Service Area Office
291 King Street, 4th Floor
London ON N6B 1R8

Telephone: 519-675-7680
Facsimile: 519-675-7685

Bureau régional de services de London
291, rue King, 4ièm étage
London ON N6B 1R8

Téléphone: 519-675-7680
Télécopieur: 519-675-7685

<input type="checkbox"/> Licensee Copy/Copie du Titulaire <input checked="" type="checkbox"/> Public Copy/Copie Public		
Date(s) of inspection/Date de l'inspection	Inspection No/ d'inspection	Type of Inspection/Genre d'inspection
January 19, 2011	2011-145-2301-Jan17165102	L-000600 -11 Critical Incident L-00003 Follow-up
Licensee/Titulaire		
1230839 Ontario Limited, 708 Wellington Street, Wallaceburg, ON N8A2Y6		
Long-Term Care Home/Foyer de soins de longue durée		
Brouillette Manor, 11900 Brouillette Court, Tecumseh, ON N8N 4X8		
Name of Inspector(s)/Nom de l'inspecteur(s)		
Karin Mussart, #145		
Inspection Summary/Sommaire d'inspection		
The purpose of this inspection was to conduct a critical incident inspection follow-up related to a Safe and Secure Home.		
During the course of the inspection, the inspector spoke with the Administrator and the Director of Care.		
During the course of the inspection, the inspector reviewed the policy and procedures related to wandering residents, conducted a visual inspection of all exit doors, leading to the outside, and resident room areas.		
The following Inspection Protocols were used during this inspection:		
• Safe and Secure Home		
Findings of Non-Compliance were found during this inspection. The following action was taken:		
1 WN		

NON-COMPLIANCE / (Non-respectés)



**Ministry of Health and
Long-Term Care**
**Ministère de la Santé et
des Soins de longue durée**

**Inspection Report
under the *Long
Term Care Homes
Act, 2007***

**Rapport
d'inspection prévue
le *Loi de 2007 les
foyers de soins de
longue durée***

Definitions/Définitions

WN – Written Notifications/Avis écrit

VPC – Voluntary Plan of Correction/Plan de redressement volontaire

DR – Director Referral/Référé au directeur

CO – Compliance Order/Ordre de conformité

WAO – Work and Activity Order/Ordre: travaux et activités

The following constitutes written notification of non-compliance under paragraph 1 of section 152 of the LTCHA.

Non-compliance with requirements under the *Long-Term Care Homes Act, 2007* (LTCHA) was found. (A requirement under the LTCHA includes the requirements contained in the items listed in the definition of "requirement under this Act" in subsection 2(1) of the LTCHA.)

Le suivant constitue un avis d'écrit de l'exigence prévue le paragraphe 1 de section 152 de les foyers de soins de longue durée.

Non-respect avec les exigences sur le *Loi de 2007 les foyers de soins de longue durée* à trouvé. (Une exigence dans le loi comprend les exigences contenues dans les points énumérés dans la définition de "exigence prévue par la présente loi" au paragraphe 2(1) de la loi.

WN #1: The Licensee has failed to comply with *LTCHA, 2007*, S.O. 2007, c.8, s.5. Every licensee of a long-term care home shall ensure that the home is a safe and secure environment for its residents.

Findings:

- During inspection conducted January 19, 2011, the Administrator and the Environmental Health Inspector checked all doors in the Home that lead to the outside and determined that there was no audible alarm to indicate that the doors was open.
- The Administrator and the Environmental Health Inspector determined that there is not a audio visual enunciator that is connected to the nurse's station nearest to the door and has a manual reset switch at each door.

Inspector ID #: #145

Signature of Licensee or Representative of Licensee
Signature du Titulaire du représentant désigné

**Signature of Health System Accountability and Performance Division
representative/Signature du (de la) représentant(e) de la Division de la responsabilisation et de la performance du système de santé.**

Title: **Date:** **Date of Report:** (if different from date(s) of inspection).

February 7, 2011