



**Ministry of Health and
Long-Term Care**

**Inspection Report under
the Long-Term Care
Homes Act, 2007**

**Ministère de la Santé et des
Soins de longue durée**

**Rapport d'inspection
prévues le Loi de 2007 les
foyers de soins de longue**

Health System Accountability and Performance
Division
Performance Improvement and Compliance Branch
Division de la responsabilisation et de la
performance du système de santé
Direction de l'amélioration de la performance et de la
conformité

London Service Area Office
291 King Street, 4th Floor
LONDON, ON, N6B-1R8
Telephone: (519) 675-7680
Facsimile: (519) 675-7685

Bureau régional de services de London
291, rue King, 4^{ème} étage
LONDON, ON, N6B-1R8
Téléphone: (519) 675-7680
Télécopieur: (519) 675-7685

Public Copy/Copie du public

Date(s) of inspection/Date(s) de l'inspection	Inspection No/ No de l'inspection	Type of Inspection/Genre d'inspection
Sep 8, 16, 28, 2011	2011_023155_0009	Complaint

Licensee/Titulaire de permis

PROVINCIAL NURSING HOME LIMITED PARTNERSHIP
1090 MORAND STREET, WINDSOR, ON, N9G-1J6

Long-Term Care Home/Foyer de soins de longue durée

ERRINRUNG NURSING HOME, DIVISION OF PROVINCIAL NURSING HOME LIMITED PARTNERSHIP
67 Bruce Street, P.O. Box 7069, THORNBURY, ON, N0H-2P0

Name of Inspector(s)/Nom de l'inspecteur ou des inspecteurs

SHARON PERRY (155)

Inspection Summary/Résumé de l'inspection

The purpose of this inspection was to conduct a Complaint inspection.

During the course of the inspection, the inspector(s) spoke with General Manager, Director of Care, 2 Registered Staff, 3 Personal Support Workers, and 7 Residents.

During the course of the inspection, the inspector(s) toured the home, activated call bells in resident care areas and observed privacy curtains in resident care areas.

The following Inspection Protocols were used during this inspection:

Safe and Secure Home

Findings of Non-Compliance were found during this inspection.

NON-COMPLIANCE / NON-RESPECT DES EXIGENCES

Legend	Legendé
WN – Written Notification	WN – Avis écrit
VPC – Voluntary Plan of Correction	VPC – Plan de redressement volontaire
DR – Director Referral	DR – Aiguillage au directeur
CO – Compliance Order	CO – Ordre de conformité
WAO – Work and Activity Order	WAO – Ordres : travaux et activités

Non-compliance with requirements under the Long-Term Care Homes Act, 2007 (LTCHA) was found. (A requirement under the LTCHA includes the requirements contained in the items listed in the definition of "requirement under this Act" in subsection 2(1) of the LTCHA.)

The following constitutes written notification of non-compliance under paragraph 1 of section 152 of the LTCHA.

Le non-respect des exigences de la Loi de 2007 sur les foyers de soins de longue durée (LFSLD) a été constaté. (Une exigence de la loi comprend les exigences qui font partie des éléments énumérés dans la définition de « exigence prévue par la présente loi », au paragraphe 2(1) de la LFSLD.

Ce qui suit constitue un avis écrit de non-respect aux termes du paragraphe 1 de l'article 152 de la LFSLD.

WN #1: The Licensee has failed to comply with O.Reg 79/10, s. 17. Communication and response system
Specifically failed to comply with the following subsections:

s. 17. (1) Every licensee of a long-term care home shall ensure that the home is equipped with a resident-staff communication and response system that,
(a) can be easily seen, accessed and used by residents, staff and visitors at all times;
(b) is on at all times;
(c) allows calls to be cancelled only at the point of activation;
(d) is available at each bed, toilet, bath and shower location used by residents;
(e) is available in every area accessible by residents;
(f) clearly indicates when activated where the signal is coming from; and
(g) in the case of a system that uses sound to alert staff, is properly calibrated so that the level of sound is audible to staff. O. Reg. 79/10, s. 17 (1).

Findings/Faits saillants :

1. On September 8, 2011 at 1500 hours call bells for two resident's beds and one bathroom were not functioning and could not be activated.[O. Reg. 79/10, s.17(1)(b)]

Additional Required Actions:

VPC - pursuant to the Long-Term Care Homes Act, 2007, S.O. 2007, c.8, s.152(2) the licensee is hereby requested to prepare a written plan of correction for achieving compliance to ensure that the communication and response system is on at all times, to be implemented voluntarily.

Issued on this 28th day of September, 2011

Signature of Inspector(s)/Signature de l'inspecteur ou des inspecteurs

