

Ministry of Long-Term Care

Long-Term Care Operations Division
Long-Term Care Inspections Branch

Ottawa District

347 Preston Street, Suite 410
Ottawa, ON, K1S 3J4
Telephone: (877) 779-5559

Public Report

Report Issue Date: December 16, 2025

Inspection Number: 2025-1198-0005

Inspection Type:

Proactive Compliance Inspection

Licensee: Arnprior Regional Health

Long Term Care Home and City: The Grove Nursing Home, Arnprior

INSPECTION SUMMARY

The inspection occurred onsite on the following date(s): December 11, 12, 15, 16, 2025

The following intake(s) were inspected:

- Intake: #00164168 - Proactive Compliance Inspection

The following **Inspection Protocols** were used during this inspection:

Housekeeping, Laundry and Maintenance Services
Food, Nutrition and Hydration
Infection Prevention and Control

INSPECTION RESULTS

WRITTEN NOTIFICATION: General requirements

Ministry of Long-Term Care

Long-Term Care Operations Division
Long-Term Care Inspections Branch

Ottawa District

347 Preston Street, Suite 410
Ottawa, ON, K1S 3J4
Telephone: (877) 779-5559

NC #001 Written Notification pursuant to FLTCA, 2021, s. 154 (1) 1.

Non-compliance with: O. Reg. 246/22, s. 34 (1) 3.

General requirements

s. 34 (1) Every licensee of a long-term care home shall ensure that the following is complied with in respect of each of the organized programs required under sections 11 to 20 of the Act and each of the interdisciplinary programs required under section 53 of this Regulation:

3. The program must be evaluated and updated at least annually in accordance with evidence-based practices and, if there are none, in accordance with prevailing practices.

The maintenance program was not evaluated and updated at least annually. Review of the home's maintenance program and all relevant policies and procedures and an interview with a staff that indicated they were last updated in June 2021.

Sources: Policy: Building Operations and Preventative Maintenance #XI-A-10.00. Last updated June 2021. Policy: Maintenance Service Availability #XI-A-15.00. Last updated June 2021. Policy: Electrical and Non-electrical Equipment #XI-B-25.00. Last updated June 2021. Policy: Plumbing Repair and Maintenance #XI-B-35.00. Last updated June 2021 and interview with a staff.