

**Ministry of Long-Term Care**

Long-Term Care Operations Division  
Long-Term Care Inspections Branch

**Ottawa District**

347 Preston Street, Suite 410  
Ottawa, ON, K1S 3J4  
Telephone: (877) 779-5559

## Public Report

<b>Report Issue Date:</b> February 25, 2026
<b>Inspection Number:</b> 2026-1198-0001
<b>Inspection Type:</b> Proactive Compliance Inspection
<b>Licensee:</b> Arnprior Regional Health
<b>Long Term Care Home and City:</b> The Grove Nursing Home, Arnprior

## INSPECTION SUMMARY

The inspection occurred onsite on the following date(s): February 18, 19, 23, 24, 25, 2026

The following intake(s) were inspected:

- Intake: #00170470 -Proactive Compliance Inspection-Generator Initiative

The following **Inspection Protocols** were used during this inspection:

Safe and Secure Home

## INSPECTION RESULTS

### WRITTEN NOTIFICATION: Maintenance Services

NC #001 Written Notification pursuant to FLTCA, 2021, s. 154 (1) 1.

**Non-compliance with: O. Reg. 246/22, s. 96 (1) (b)**

**Ministry of Long-Term Care**

Long-Term Care Operations Division  
Long-Term Care Inspections Branch

**Ottawa District**

347 Preston Street, Suite 410  
Ottawa, ON, K1S 3J4  
Telephone: (877) 779-5559

Maintenance services

s. 96 (1) As part of the organized program of maintenance services under clause 19 (1) (c) of the Act, every licensee of a long-term care home shall ensure that,  
(b) there are schedules and procedures in place for routine, preventive and remedial maintenance.

A procedure for remedial, routine and preventative maintenance was not in place to support compliance with the regulations related to generator maintenance. During an interview with the Maintenance Supervisor on a day in February, 2026, they confirmed that there was no written procedures related to generator maintenance.

Sources: Record review and an interview with maintenance staff.