

# Inspection Report Under the Fixing Long-Term Care Act, 2021

### **Ministry of Long-Term Care**

Long-Term Care Operations Division Long-Term Care Inspections Branch

#### **Central East District**

33 King Street West, 4th Floor Oshawa, ON, L1H 1A1 Telephone: (844) 231-5702

## **Public Report**

Report Issue Date: August 12, 2025

Inspection Number: 2025-1022-0003

**Inspection Type:** 

Complaint

Licensee: ATK Care Inc.

Long Term Care Home and City: River Glen Haven Nursing Home, Sutton West

## **INSPECTION SUMMARY**

The inspection occurred onsite on the following date(s): August 7, 11, 12, 2025

The following intake(s) were inspected:

• Intake: #00154305 related to air temperature complaint

The following **Inspection Protocols** were used during this inspection:

Housekeeping, Laundry and Maintenance Services Infection Prevention and Control

## **INSPECTION RESULTS**

### **WRITTEN NOTIFICATION: Maintenance services**

NC #001 Written Notification pursuant to FLTCA, 2021, s. 154 (1) 1.

Non-compliance with: O. Reg. 246/22, s. 96 (2) (b)



# Inspection Report Under the Fixing Long-Term Care Act, 2021

### **Ministry of Long-Term Care**

Long-Term Care Operations Division Long-Term Care Inspections Branch

#### **Central East District**

33 King Street West, 4th Floor Oshawa, ON, L1H 1A1 Telephone: (844) 231-5702

#### Maintenance services

s. 96 (2) The licensee shall ensure that procedures are developed and implemented to ensure that,

(b) all equipment, devices, assistive aids and positioning aids in the home are kept in good repair, excluding the residents' personal aids or equipment;

The licensee failed to ensure that the thermometers used to check the home's temperature were kept in good repair

Temperature logs from late July 2025 recorded indoor temperatures above 26°C. During inspection, it was demonstrated that the thermometer in use was inaccurate, displaying 27.3°C, while calibrated devices showed approximately 22°C. It was confirmed that the equipment was faulty, uncalibrated, and had not been reported for repair, resulting in a discrepancy of 4–6 degrees.



# Inspection Report Under the Fixing Long-Term Care Act, 2021

### **Ministry of Long-Term Care**

Long-Term Care Operations Division Long-Term Care Inspections Branch

### **Central East District**

33 King Street West, 4th Floor Oshawa, ON, L1H 1A1 Telephone: (844) 231-5702