

Ministry of Long-Term Care

Long-Term Care Operations Division
Long-Term Care Inspections Branch

Hamilton District

119 King Street West, 11th Floor
Hamilton, ON, L8P 4Y7
Telephone: (800) 461-7137

Public Report

Report Issue Date: April 17, 2026

Inspection Number: 2026-1434-0002

Inspection Type:

Proactive Compliance Inspection

Licensee: United Mennonite Home for the Aged

Long Term Care Home and City: United Mennonite Home, Vineland

INSPECTION SUMMARY

The inspection occurred onsite on the following date(s): April 15 - 17, 2026.

The following intake(s) were inspected:

-Intake: #00175734 - Focused PCI - Generator Initiative

The following **Inspection Protocols** were used during this inspection:

Safe and Secure Home

INSPECTION RESULTS

WRITTEN NOTIFICATION: Specific duties re cleanliness and repair

NC #001 Written Notification pursuant to FLTCA, 2021, s. 154 (1) 1.

Ministry of Long-Term Care

Long-Term Care Operations Division
Long-Term Care Inspections Branch

Hamilton District

119 King Street West, 11th Floor
Hamilton, ON, L8P 4Y7
Telephone: (800) 461-7137

Non-compliance with: FLTCA, 2021, s. 19 (2) (c)

Accommodation services

s. 19 (2) Every licensee of a long-term care home shall ensure that,

(c) the home, furnishings and equipment are maintained in a safe condition and in a good state of repair.

During monthly preventative testing of the home's generator, documentation indicated that for a period, both elevators had not functioned when the generator power supply was activated.

Testing of the generator at the time of this inspection indicated both elevators were not functioning when the generator power supply was activated.

Sources: monthly preventative generator checklist documents; and an interview with maintenance staff #104 and others.