

**Inspection Report under
the Long-Term Care
Homes Act, 2007**

**Rapport d'inspection en vertu de
la Loi de 2007 sur les foyers de
soins de longue durée**

**Long-Term Care Operations Division
Long-Term Care Inspections Branch**

**Division des opérations relatives aux
soins de longue durée
Inspection de soins de longue durée**

Ottawa Service Area Office
347 Preston St Suite 420
OTTAWA ON K1S 3J4
Telephone: (613) 569-5602
Facsimile: (613) 569-9670

Bureau régional de services d'Ottawa
347 rue Preston bureau 420
OTTAWA ON K1S 3J4
Téléphone: (613) 569-5602
Télécopieur: (613) 569-9670

Public Copy/Copie du rapport public

Report Date(s) / Date(s) du Rapport	Inspection No / No de l'inspection	Log # / No de registre	Type of Inspection / Genre d'inspection
Jan 6, 2022	2021_505103_0017	017906-21	Complaint

Licensee/Titulaire de permis

Belcrest Nursing Homes Limited
250 Bridge Street West Belleville ON K8P 5N3

Long-Term Care Home/Foyer de soins de longue durée

Belmont Long Term Care Facility
250 Bridge Street West Belleville ON K8P 5N3

Name of Inspector(s)/Nom de l'inspecteur ou des inspecteurs

DARLENE MURPHY (103)

Inspection Summary/Résumé de l'inspection

The purpose of this inspection was to conduct a Complaint inspection.

This inspection was conducted on the following date(s): December 22-24, 2021.

Log #017906-21-complaint related to air temperature.

During the course of the inspection, the inspector(s) spoke with residents, a Housekeeper, Registered Practical Nurses (RPN), Registered Nurses (RN), the Director of Care (DOC) and the Administrator.

During the course of the inspection, the inspector reviewed a resident health care record, temperature logs for three resident units during November 2021, and the home's policy, "Prevention of Heat Related Illness, #RCSM-E-140".

**The following Inspection Protocols were used during this inspection:
Safe and Secure Home**

During the course of this inspection, Non-Compliances were issued.

1 WN(s)

0 VPC(s)

0 CO(s)

0 DR(s)

0 WAO(s)

NON-COMPLIANCE / NON - RESPECT DES EXIGENCES

<p>Legend</p> <p>WN – Written Notification VPC – Voluntary Plan of Correction DR – Director Referral CO – Compliance Order WAO – Work and Activity Order</p>	<p>Légende</p> <p>WN – Avis écrit VPC – Plan de redressement volontaire DR – Aiguillage au directeur CO – Ordre de conformité WAO – Ordres : travaux et activités</p>
<p>Non-compliance with requirements under the Long-Term Care Homes Act, 2007 (LTCHA) was found. (a requirement under the LTCHA includes the requirements contained in the items listed in the definition of "requirement under this Act" in subsection 2(1) of the LTCHA).</p> <p>The following constitutes written notification of non-compliance under paragraph 1 of section 152 of the LTCHA.</p>	<p>Le non-respect des exigences de la Loi de 2007 sur les foyers de soins de longue durée (LFSLD) a été constaté. (une exigence de la loi comprend les exigences qui font partie des éléments énumérés dans la définition de « exigence prévue par la présente loi », au paragraphe 2(1) de la LFSLD.</p> <p>Ce qui suit constitue un avis écrit de non-respect aux termes du paragraphe 1 de l'article 152 de la LFSLD.</p>

WN #1: The Licensee has failed to comply with O.Reg 79/10, s. 21. Air temperature

Findings/Faits saillants :

1. The licensee failed to ensure the home was maintained at a minimum temperature of 22 degrees Celsius.

Temperature log records for three resident units during November 2021 were reviewed. One of the three units (Green Acres) was noted to have numerous dates and times whereby the home was not maintained at a minimum temperature of 22 degrees Celsius.

Sources: November 2021 temperature logs, interview with Administrator. [s. 21.]

Issued on this 10th day of January, 2022

Signature of Inspector(s)/Signature de l'inspecteur ou des inspecteurs

Original report signed by the inspector.