



Ministry of Health and  
Long-Term Care

Inspection Report under  
the Long-Term Care  
Homes Act, 2007

Ministère de la Santé et des  
Soins de longue durée

Rapport d'inspection sous la  
Loi de 2007 sur les foyers de  
soins de longue durée

Health System Accountability and  
Performance Division  
Performance Improvement and  
Compliance Branch

Division de la responsabilisation et de la  
performance du système de santé  
Direction de l'amélioration de la  
performance et de la conformité

Ottawa Service Area Office  
347 Preston St, 4th Floor  
OTTAWA, ON, K1S-3J4  
Telephone: (613) 569-5602  
Facsimile: (613) 569-9670

Bureau régional de services d'Ottawa  
347, rue Preston, 4iém étage  
OTTAWA, ON, K1S-3J4  
Téléphone: (613) 569-5602  
Télécopieur: (613) 569-9670

**Public Copy/Copie du public**

Report Date(s) / Date(s) du Rapport	Inspection No / No de l'inspection	Log # / Registre no	Type of Inspection / Genre d'inspection
Dec 19, 2012	2012_204133_0009	O-000643- 12	Complaint

**Licensee/Titulaire de permis**

THE PERLEY AND RIDEAU VETERANS' HEALTH CENTRE  
1750 Russell Road, OTTAWA, ON, K1G-5Z6

**Long-Term Care Home/Foyer de soins de longue durée**

THE PERLEY AND RIDEAU VETERANS' HEALTH CENTRE  
1750 RUSSELL ROAD, OTTAWA, ON, K1G-5Z6

**Name of Inspector(s)/Nom de l'inspecteur ou des inspecteurs**

JESSICA LAPENSEE (133)

**Inspection Summary/Résumé de l'inspection**

The purpose of this inspection was to conduct a Complaint inspection.

This inspection was conducted on the following date(s): December 10, 11 - 2012

During the course of the inspection, the inspector(s) spoke with the Administrator, the Director of Support Services, the Manager of Support Services, nursing staff and residents.

During the course of the inspection, the inspector(s) monitored air temperatures in various areas throughout the home, observed the available supply of linen, face cloths and towels throughout the home.

The following Inspection Protocols were used during this inspection:



Ministry of Health and  
Long-Term Care

Inspection Report under  
the Long-Term Care  
Homes Act, 2007

Ministère de la Santé et des  
Soins de longue durée

Rapport d'inspection sous la  
Loi de 2007 sur les foyers de  
soins de longue durée

## Safe and Secure Home

**Findings of Non-Compliance were found during this inspection.**

<b>NON-COMPLIANCE / NON - RESPECT DES EXIGENCES</b>	
<b>Legend</b>  WN – Written Notification VPC – Voluntary Plan of Correction DR – Director Referral CO – Compliance Order WAO – Work and Activity Order	<b>Legendé</b>  WN – Avis écrit VPC – Plan de redressement volontaire DR – Aiguillage au directeur CO – Ordre de conformité WAO – Ordres : travaux et activités
Non-compliance with requirements under the Long-Term Care Homes Act, 2007 (LTCHA) was found. (A requirement under the LTCHA includes the requirements contained in the items listed in the definition of "requirement under this Act" in subsection 2(1) of the LTCHA.)	Le non-respect des exigences de la Loi de 2007 sur les foyers de soins de longue durée (LFSLD) a été constaté. (Une exigence de la loi comprend les exigences qui font partie des éléments énumérés dans la définition de « exigence prévue par la présente loi », au paragraphe 2(1) de la LFSLD.)
The following constitutes written notification of non-compliance under paragraph 1 of section 152 of the LTCHA.	Ce qui suit constitue un avis écrit de non-respect aux termes du paragraphe 1 de l'article 152 de la LFSLD.

**WN #1: The Licensee has failed to comply with O.Reg 79/10, s. 21. Every licensee of a long-term care home shall ensure that the home is maintained at a minimum temperature of 22 degrees Celsius. O. Reg. 79/10, s. 21.**

## Findings/Faits saillants :



Ministry of Health and  
Long-Term Care

Inspection Report under  
the Long-Term Care  
Homes Act, 2007

Ministère de la Santé et des  
Soins de longue durée

Rapport d'inspection sous la  
Loi de 2007 sur les foyers de  
soins de longue durée

- 
1. The licensee has failed to comply with O. Reg. 79/10, s. 21 in that not all areas of the home are maintained at a minimum temperature of 22 degrees Celsius.

Over the course of the two day complaint inspection, the inspector verified the air temperature in various areas throughout the Home. The air temperature in the Rideau 2SE tub room, as well as in the majority of tub rooms and shower rooms throughout the Gatineau and Ottawa buildings, was noted to be below 22 degrees Celsius (for example – on Dec. 11th, G1SE shower room - 18.2C, O2SW tub room - 19.2C, R2SE tub room - 20.7C). Air temperature in the main link corridors between the central area and the Gatineau and Ottawa buildings was also noted to be below 22 degrees Celsius during the inspection (for example, on Dec 10th, at the green couch, Ottawa link - 20.5C, Gatineau link - 20.9C). [s. 21.]

---

Issued on this 19th day of December, 2012

Signature of Inspector(s)/Signature de l'inspecteur ou des inspecteurs

*Jessica Lopensée*