

Ministry of Long-Term Care
Long-Term Care Operations Division
Long-Term Care Inspections Branch

Toronto District
5700 Yonge Street, 5th Floor
Toronto, ON, M2M 4K5
Telephone: (866) 311-8002

Public Report

Report Issue Date: February 18, 2026

Inspection Number: 2026-1359-0002

Inspection Type:
Proactive Compliance Inspection

Licensee: 2063414 Investment LP, by its general partner, 2063414 Ontario Limited

Long Term Care Home and City: Weston Terrace Community, Toronto

INSPECTION SUMMARY

The inspection occurred onsite on the following date(s): February 11 - 13, and 17 - 18, 2026.

The following intake(s) were inspected:

- Intake: #00170080 - Proactive Compliance Inspection

The following **Inspection Protocols** were used during this inspection:

Housekeeping, Laundry and Maintenance Services
Safe and Secure Home
Infection Prevention and Control

INSPECTION RESULTS

WRITTEN NOTIFICATION: Accommodations Services

NC #001 Written Notification pursuant to FLTCA, 2021, s. 154 (1) 1.

Non-compliance with: FLTCA, 2021, s. 19 (2) (c)

Accommodation services

s. 19 (2) Every licensee of a long-term care home shall ensure that,

(c) the home, furnishings and equipment are maintained in a safe condition and in a good state of repair.

Ministry of Long-Term Care
Long-Term Care Operations Division
Long-Term Care Inspections Branch

Toronto District
5700 Yonge Street, 5th Floor
Toronto, ON, M2M 4K5
Telephone: (866) 311-8002

During an observation, it was noted that interior areas (walls and baseboards) on first, third, and fourth floor units were not maintained in a good state of repair.

Director of Environment Services (DES) confirmed that the identified walls and baseboards were not in a good state of repair.

Sources: Observation, interview with the DES, Annual Evaluation of maintenance program, maintenance schedule.

WRITTEN NOTIFICATION: Doors In A Home

NC #002 Written Notification pursuant to FLTCA, 2021, s. 154 (1) 1.

Non-compliance with: O. Reg. 246/22, s. 12 (1) 2.

Doors in a home

s. 12 (1) Every licensee of a long-term care home shall ensure that the following rules are complied with:

2. All doors leading to secure outside areas that preclude exit by a resident, including balconies and terraces, must be equipped with locks to restrict unsupervised access to those areas by residents.

During an observation on third and fourth floors, the balcony door was noted to be unlocked, resulting in unrestricted resident access to the balcony in freezing weather conditions.

Sources: Observation; review of home's policy, and interviews with the DES, Registered Nurse (RN) and Registered Practical Nurse (RPN).