



Ministry of Health and Long-Term Care

Ministère de la Santé et des Soins de longue durée

Inspection Report under the Long-Term Care Homes Act, 2007

Rapport d'inspection sous la Loi de 2007 sur les foyers de soins de longue durée

Health System Accountability and Performance Division
Performance Improvement and Compliance Branch

Division de la responsabilisation et de la performance du système de santé
Direction de l'amélioration de la performance et de la conformité

Hamilton Service Area Office
119 King Street West, 11th Floor
HAMILTON, ON, L8P-4Y7
Telephone: (905) 546-8294
Facsimile: (905) 546-8255

Bureau régional de services de Hamilton
119, rue King Ouest, 11ième étage
HAMILTON, ON, L8P-4Y7
Téléphone: (905) 546-8294
Télécopieur: (905) 546-8255

Public Copy/Copie du public

Report Date(s) / Date(s) du Rapport	Inspection No / No de l'inspection	Log # / Registre no	Type of Inspection / Genre d'inspection
Feb 11, 2013	2013_189120_0014	H-000073-13	Critical Incident System

Licensee/Titulaire de permis

THE REGIONAL MUNICIPALITY OF PEEL
10 PEEL CENTRE DRIVE, BRAMPTON, ON, L6T-4B9

Long-Term Care Home/Foyer de soins de longue durée

PEEL MANOR
525 MAIN STREET NORTH, BRAMPTON, ON, L6X-1N9

Name of Inspector(s)/Nom de l'inspecteur ou des inspecteurs

BERNADETTE SUSNIK (120)

Inspection Summary/Résumé de l'inspection



The purpose of this inspection was to conduct a Critical Incident System inspection.

This inspection was conducted on the following date(s): January 29, 2013

This visit was made in response to a critical incident report filed by the home on January 28, 2013 regarding an incident where a magnetically locked stairwell door was released by a resident playing with a fire alarm pull station. The resident entered the stairwell and fell but was not injured.

During the course of the inspection, the inspector(s) spoke with the Administrator, Director of Care, Environmental Services Supervisor and a maintenance person regarding a fire alarm pull station located on the 2nd floor.

During the course of the inspection, the inspector(s) toured the 2nd floor and tested stairwell doors and tested a newly installed cover and alarm on a pull station and reviewed a service report from Robertson Fire Equipment.

The following Inspection Protocols were used during this inspection:
Safe and Secure Home

There are no findings of Non-Compliance as a result of this inspection.

NON-COMPLIANCE / NON - RESPECT DES EXIGENCES	
Legend	Legendé
WN – Written Notification	WN – Avis écrit
VPC – Voluntary Plan of Correction	VPC – Plan de redressement volontaire
DR – Director Referral	DR – Aiguillage au directeur
CO – Compliance Order	CO – Ordre de conformité
WAO – Work and Activity Order	WAO – Ordres : travaux et activités



Ministry of Health and
Long-Term Care

Ministère de la Santé et des
Soins de longue durée

Inspection Report under
the Long-Term Care
Homes Act, 2007

Rapport d'inspection sous la
Loi de 2007 sur les foyers de
soins de longue durée

Non-compliance with requirements under the Long-Term Care Homes Act, 2007 (LTCHA) was found. (A requirement under the LTCHA includes the requirements contained in the items listed in the definition of "requirement under this Act" in subsection 2(1) of the LTCHA.)

The following constitutes written notification of non-compliance under paragraph 1 of section 152 of the LTCHA.

Le non-respect des exigences de la Loi de 2007 sur les foyers de soins de longue durée (LFSLD) a été constaté. (Une exigence de la loi comprend les exigences qui font partie des éléments énumérés dans la définition de « exigence prévue par la présente loi », au paragraphe 2(1) de la LFSLD.

Ce qui suit constitue un avis écrit de non-respect aux termes du paragraphe 1 de l'article 152 de la LFSLD.

Issued on this 11th day of February, 2013

Signature of Inspector(s)/Signature de l'inspecteur ou des inspecteurs

B. Susnik